Phone:080-22945350 **Email:**cewwmwest@bwssb.gov.in

BENGALURU WATER SUPPLY AND SEWERAGE BOARD
Office of the Chief Engineer (Waste Water Management) -WEST
6th Floor, Cauvery Bhavan, KG Road, Bangalore - 560009

No. BWSSB/CE(WWM-WEST)/ACE(WWM-STP-W)/DCE(WWM-E&W)/TA-2/636 /2025-26 Dt: 02/07/2

ADDENDUM/CORRIGENDUM

Sub: Tender for Improvement work of Installation, Supply & Commissioning of Odour Control Unit (OCU) at Hebbal 100 MLD UWTP coming under AEE(WWM-STP-H&A.1) sub division.(2nd Call).

Ref: IFT No. BWSSB/CE(WWM-W)/ACE(WWM-STP-W)/DCE(WWM-E&W)/TA-2/519/2025-26 Dated:21.06.2025.

~*~*~*~

With reference to the above subject, invitation for the tender was invited vide IFT mentioned in the above reference letter. This addendum/corrigendum indicates the replies to pre bid queries.

Chief Engineer(WWM-W)
BWSSB

Encl: Replies to the Pre-Bid Queries.

Scanned with OKEN Scanner

REPLY TO PRE-BID QUERIES FOR Tender for the Improvement work of Installation, Supply & Commissioning of Odour Control Unit (OCU) at Hebbal 100 MLD UWTP coming under AEE(WWM-STP-H&A.1) sub division.(2nd Call).

IFT No. BWSSB/CE(WWM-W)/ACE(WWM-STP-W)/DCE(WWM-E&W)/TA-2/519/2025-26 Dated:21.06.2025

Tender No. BWSSB/2025-26/WT/WORK_INDENT2305/CALL-2

Sl.No	Tender Volume	Clause No	Page No	Subject	Tenderers Query	Reply
A: Process & Mechanical						
1.	Tender documents – Section 7	Technical Specification	52 of 63	PTU description	As per the tender the capacity of extractor fan has been provided for PTU. We presume that PTU is Pre Treatment Units and those shall be Coarse Screens, Fine Screens and Grit Chamber. These three units are the most odour emanating units	Tender Condition prevails
2	Tender documents – Section 7	Technical Specification	53 of 63	Bio-Filter Media	We propose to offer more modern media with higher life and surface area for better performance. The specifications for the Bio-Filter Media are the minimum criteria and that any better specification/worldwide standard shall be allowed	Tender Condition prevails
3	Tender documents – Section 7	Technical Specification	53 of 63	Manufacturer Eligibility criteria	We are the channel partners for Pure Air Solutions, a 25 year old Netherlands based Company in the field of Odour Control. Having entered the India Market recently, we have several orders from prestigious customers in different stages of completion. We request that PO Copies of 5 India Installations maybe accepted. The International references are numerous and we are the pioneers in this field	Tender Condition prevails
4	Tender documents – Section 7	Technical Specification	53 of 63	Activated Carbon Filter	The design is to be based on 6 Air Changes for odour causing tanks. Following query #1, it is understood that odour causing tanks are the PTU units ie. Coarse Screens, Fine Screens and Grit Chamber	Tender Condition prevails
5	Tender documents – Section 7	Technical Specification	52 and 53 of 63	Tank Sizes	Please provide us the GA drawings of the PTU Units so as to enable us to calculate the volume and therefore the capacity of OCU considering 6 air changes.	Enclosed

Chief Engineer(WWM-W)
BWSSB

Scanned with OKEN Scanner